



HÆRENS TEKNISKE TJENESTE
Arsenalvej 55, Postbox 220, 9800 Hjørring

Telefon: 99 24 11 11 - Selvvalg 99 24 + lok.nr.
Telex 6 78 84 hmakhj dk Tlgr. adr. Militeknik
Telefax: 99 24 14 09

FN/kc

HTT TSV XNR. : UB
601.4
9508012-092 25 SEP 1996

Nr.:	TLA.601.4/ 23862
Dato:	26. SEP. 1996

(Bedes anført ved besvarelse)

Til CUBIC-Modulsystem A/S
Skjoldborgsgade 21
9700 Brønderslev

Emne: Vibrationstest af draw-out system.

Bilag: TLA rapport 218.

Hermed fremsendes som bilag rapport TLA 218 over udført vibrationstest af draw-out system.

Faktura - omfattende de med afprøvningen forbundne udgifter - vil blive tilsendt særskilt.

e.b.

P. HAUMANN
teknikumingeniør
Chef for Laboratoriesektionen



ARMY TECHNICAL SERVICE

LABORATORY BRANCH/ENVIROMENT LABORATORY

Subject: Draw-out system

Type:

Manufacturer: CUBIC-Modulsystem A/S

Type:

Applicant: CUBIC-Modulsystem A/S

Sign: F. Nielsen

VIBRATION TEST OF DRAW-OUT SYSTEM

The exposure was carried out at the Danish Army Technical Services, TSVAFD/LABSEK the Environmental Laboratory in the period 12 to 16 AUG 1996.

SPECIFICATION: Germanischer Lloyd.
Regulations for the performance of Type Tests part 1.
The Requirements for Electrical/electronic, Computers and Peripherals.

REF. SPECIFICATION: IEC Publication 68-2-6 Test Fc Sinusoidal Vibration.

TESTING EQUIPMENT: See instrument list page 2.

TESTING SUBJECTS: One Draw-out System.

RESULT: The vibration test in accordance with specification and supplementary electrical function test was carried through with a satisfactory result.