


TITLE Declaration of Conformity – FLOOD LIGHT Emergency Luminaire, SLA Battery					
PREPARED: G Grover	CHECKED: Stephen Charlton	APPROVED: Stephen Charlton	DOCUMENT NUMBER: FPDC001	ISSUE: B	
DATE: 6/10/20	DATE: 7/10/20	DATE: 7/10/20	DATE: 7/10/20	DATE: 7/10/20	

Product covered by this declaration –

FL210LED	FLNXS210LED	FLNRF210LED
----------	-------------	-------------

Product Description –

FLOOD LIGHT LED Emergency Non-maintained Luminaire variants, Monitored & Non-monitored. IP20 LED Flood luminaire comprising metal enclosure containing control gear, Sealed Lead Acid rechargeable battery and two 10W LED lamp heads.

Declaration –

The product listed above is designed and manufactured to comply with the relevant standards as listed below, provided it is correctly installed and maintained.

Applicable Standards –

AS/NZS 60598.1:2013	Luminaires General requirements and tests
AS/NZS 60598.2.22:2005	Luminaires Particular requirements - Luminaires for emergency lighting
AS/NZS CISPR 15	Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment
AS/NZS 2293.3:2005	Emergency lighting and exit signs for buildings - Emergency luminaires and exit signs



Signature:

Signed for and on behalf of ABB Australia Pty Ltd

Name & position, as authorized by the issuer	Stephen Charlton, Global Product Manager – EML - Asia
Date of Issue	7/10/2020