


TITLE Declaration of Conformity – QUICKFIT Large/Jumbo LED Exit Sign, LiFePO4 Battery					
PREPARED: G Grover	CHECKED: Stephen Charlton	APPROVED: Stephen Charlton	DOCUMENT NUMBER: QPDC003	ISSUE: A	
DATE: 26/07/18	DATE: 30/07/18	DATE: 30/07/18	DATE: 27/07/18	DATE: 27/07/18	

Product covered by this declaration –

PQFJLED-1	PQFJNRFLED-1	PQFJNXSLED-1	PQFLED-1	PQFLNRFLED-1	PQFLNXSLED-1
PQFJLED-2	PQFJNRFLED-2	PQFJNXSLED-2	PQFLED-2	PQFLNRFLED-2	PQFLNXSLED-2
PQFJLED-3	PQFJNRFLED-3	PQFJNXSLED-3	PQFLED-3	PQFLNRFLED-3	PQFLNXSLED-3
PQFJLED-5	PQFJNRFLED-5	PQFJNXSLED-5	PQFLED-5	PQFLNRFLED-5	PQFLNXSLED-5
PQFJLED-6	PQFJNRFLED-6	PQFJNXSLED-6	PQFLED-6	PQFLNRFLED-6	PQFLNXSLED-6

Product Description –

QUICKFIT Large/Jumbo LED Exit variants, Monitored & Non-monitored. Exit sign comprising frame containing control gear, LED light source and LiFePO4 battery pack, diffusers, and mounting/connection bracket.

Declaration –

The product listed above is designed and manufactured to comply with the relevant standards as listed below, provided it is correctly installed and maintained.

Applicable Standards –

AS/NZS 60598.1:2013	Luminaires General requirements and tests
AS/NZS 60598.2.22:2005	Luminaires Particular requirements - Luminaires for emergency lighting
AS/NZS 2293.3:2005	Emergency lighting and exit signs for buildings Emergency luminaires and exit signs
AS/NZS CISPR 15	Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment



Signature:

Signed for and on behalf of ABB Australia Pty Ltd

Name & position, as authorized by the issuer	Stephen Charlton, LBU R&D Manager - Australia
Date of Issue	30/07/2018