

Supplier Declaration of Conformity (SDOC)

(in accordance with ISO/IEC 17050-1:2004)



SDoC Identification Number: NHPISO.003

NHP Electrical Engineering Products (N.Z.) Ltd
118a Carbine Road
Mt Wellington
Auckland 1060
New Zealand
NZ Company No: 931377
Telephone +64 9 276 1967
Fax +64 800 329 647
www.nhp-nz.com

NHP Electrical Engineering Products Pty Ltd
43-67 River Street
Richmond
Victoria 3121
Australia
A.B.N. 84 004 304 812
Telephone +61 3429 2999
Fax +61 3429 1075
www.nhp.com.au

Product details:

Product model:

NHP ISO - Catalogue No. ISOSW110xxx, ISOSW115xxx & ISOSW120xxx

Description/Ratings:

Rated Current: 10A, 15A & 20A
Voltage rating: 250V 50Hz
Single phase
Number of Switching Poles: 2
AC23 rating: 10A, 15A & 20A
M-Rating: M80, M150
IP rating: IP66

The products listed above is in conformity with the following Standard(s)/Normative Documents:

Standard/Document:

AS/NZS 3112:2011 inc. amendment 1
AS/NZS 3133:2011 inc. amendment 1 and 2
AS/NZS 3947.3:2001

Test reports/Certificates:

TUV016970EA Certificate of Approval - AS/NZS 3112:2011 inc. amendment 1 and AS/NZS 3133:2011 inc. amendment 1 and 2
TR4700 - ITACS Test report - AS/NZS 3947.3:2001

Product Markings:

RCM mark



Name: Christian James

Position: Product Manager Plug/Sockets & Terminations

Date: 30/04/2014

**Signature of
Authorised Person:**

