

Supplier Declaration of Conformity (SDOC)

(in accordance with ISO/IEC 17050-1:2004)



SDoC Identification Number: NHPMOD6.008

NHP Electrical Engineering Products (N.Z.) Ltd

118a Carbine Road
Mt Wellington
Auckland 1060
New Zealand
NZ Company No: 931377
Telephone +64 9 276 1967
Fax +64 800 329 647
www.nhp-nz.com

NHP Electrical Engineering Products Pty Ltd

43-67 River Street
Richmond
Victoria 3121
Australia
A.B.N. 84 004 304 812
Telephone +61 3429 2999
Fax +61 3429 1075
www.nhp.com.au

Product details:

Product model:

NHP MOD6 (RCBO) – Catalogue No M6RCBTxxxxxx

Description/Ratings:

Breaking capacity: 6kA
Rated Residual Current: 30mA
Number of poles: 3 pole and neutral
Current Rating: 6, 10, 16, 20, 25, 32, 40, 50 & 63 A
RCD Type: A
Curve Type: C
Voltage: 400/415VAC
Frequency: 50/60Hz

The products listed above is in conformity with the following Standard(s)/Normative Documents:

Standard/Document:

AS/NZS-61009-1

Test reports/Certificates:

ESV220008

Product Markings:

Approval No: RCM label

Name: Nelson Christopher Alexander

Position: Commercial Engineer - Circuit Protection & High Powered Switching

Date: 22/02/2022

**Signature of
Authorised Person:**

