Supplier Declaration of Conformity (SDOC)

(in accordance with ISO/IEC 17050-1:2004)



SDoC	Identification Number:	NHPMOD6.005

NHP Electrical Engineering Products (N.Z.) Ltd

118a Carbine Road Mt Wellington Auckland 1060 New Zealand NZ Company No: 93137

NZ Company No: 931377 Telephone +64 9 276 1967 Fax +64 800 329 647 www.nhp-nz.com

NHP Electrical Engineering Products Pty Ltd

43-67 River Street Richmond Victoria 3121 Australia A.B.N. 84 004 304 812 Telephone +61 3429 2999 Fax +61 3429 1075 www.nhp.com.au

-	1				• 1	
Pi	ኅስሰ	luci	•	Δ	01	0.
	w	ш			al.	

Product model:

NHP MOD6 RCBO's - Catalogue No MOD6RCBO2xxxx

Description/Ratings:

Breaking capacity: 6kA

Rated Residual Current: 10mA & 30mA

RCD Type: A & AC

Number of poles: 1P+N (Width: 36mm) Current Rating: 10A, 16A, 20A, 25A & 32A

Curve Type: C Voltage: 230VAC

The products listed above is in conformity with the following Standard(s)/Normative Documents:

Standard/Document:

AS/NZS-61009-1

Test reports/Certificates:

Approval No: N17482 or RCM mark

N17482- Certificate of Approval from NSW Department of Fair Trading

Product Markings:

Name:	Justin Charlot
Position:	Product Manager MCB, RCDs and Isolators

Date:	Signature of Authorised Person:	Swellens