

# Supplier Declaration of Conformity (SDOC)

(in accordance with ISO/IEC 17050-1:2004)



**SDoC Identification Number:** NHPMOD6.003

**NHP Electrical Engineering Products (N.Z.) Ltd**  
118a Carbine Road  
Mt Wellington  
Auckland 1060  
New Zealand  
NZ Company No: 931377  
Telephone +64 9 276 1967  
Fax +64 800 329 647  
www.nhp-nz.com

**NHP Electrical Engineering Products Pty Ltd**  
43-67 River Street  
Richmond  
Victoria 3121  
Australia  
A.B.N. 84 004 304 812  
Telephone +61 3429 2999  
Fax +61 3429 1075  
www.nhp.com.au

## Product details:

### Product model:

NHP MOD6 RCBO's – Catalogue No M6RCBSxxxxx

### Description/Ratings:

Breaking capacity: 6kA  
Rated Residual Current: 30mA  
RCD Type: A & AC  
Number of poles: 1P+N (Width: 18mm)  
Current Rating: 6A, 10A, 16A, 20A, 25A & 32A  
Curve Type: C  
Voltage: 230VAC

## The products listed above is in conformity with the following Standard(s)/Normative Documents:


### Standard/Document:

AS/NZS-61009-1

### Test reports/Certificates:

NSW24576– Certificate of Approval from NSW Department of Fair Trading

### Product Markings:

Approval No: NSW24576 or RCM  mark

**Name:** Justin Charlot

**Position:** Product Manager MCB, RCDs and Isolators

**Date:** 26/06/2013

**Signature of  
Authorised Person:**