

# Supplier Declaration of Conformity (SDOC)

(in accordance with ISO/IEC 17050-1:2004)



**SDoC Identification Number:** NHPNLINE.001

**NHP Electrical Engineering Products (N.Z.) Ltd**

118a Carbine Road  
Mt Wellington  
Auckland 1060  
New Zealand  
NZ Company No: 931377  
Telephone +64 9 276 1967  
Fax +64 800 329 647  
www.nhp-nz.com

**NHP Electrical Engineering Products Pty Ltd**

43-67 River Street  
Richmond  
Victoria 3121  
Australia  
A.B.N. 84 004 304 812  
Telephone +61 3429 2999  
Fax +61 3429 1075  
www.nhp.com.au

**Product details:**

**Product model:**

NHP NLINE - Catalogue No. NL120S, NL120L and NL320L

**Description/Ratings:**

Rated Current: 20A  
IP66  
Voltage rating: 250V 50Hz (NL120S & NL120L) / 500V 50Hz (NL320L)  
Number of Switching Poles: 2 (NL120S & NL120L) / 3 (NL320L)  
AC21 rating: 20A, AC22 rating: 20A, AC23 rating: 12A  
M-Rating: M100 (NL120S) / M120 (NL120L & NL320L)

**The products listed above is in conformity with the following Standard(s)/Normative Documents:**

**Standard/Document:**

AS/NZS 3133:2008 Inc. Amendment 1 and 2  
AS/NZS 3947.3:2001  
AS 60529

**Test reports/Certificates:**

TUV016976EA Certificate of Approval - 3133:2008 Inc. Amendment 1 and 2

**Product Markings:**

RCM mark



**Name:** Christian James

**Position:** Product Manager Plug/Sockets & Terminations

**Date:** 30/04/2014

**Signature of  
Authorised Person:**

