

Certificate No. 11526

ASTA CERTIFICATION SERVICES

(Incorporated in the year 1938)

23/24 Market Place, Rugby, CV21 3DU, England

Laboratory Ref. No. B/1901

CERTIFICATE OF

SHORT-CIRCUIT RATING

APPARATUS: LOW VOLTAGE SWITCHGEAR AND CONTROLGEAR ASSEMBLY OF BUSBARS
SUITABLE FOR USE ON TN AND TT SYSTEMS.

DESIGNATION: SYSTEM 7000 AND SYSTEM 2000

MANUFACTURER: CUBIC-MODULSYSTEM A/S, BROENDERSLEV, DENMARK

TESTED BY: BRITISH SHORT-CIRCUIT TESTING STATION, HEBBURN, ENGLAND

DATE(S) OF TESTS: 8th November 1990

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in this Certificate has been subjected to the series of proving tests in accordance with sub-clauses 8.2.3.2.3 b) and d) of IEC 439-1:1985, EN60 439-1:1990 and BS 5486:Part 1:1990

The results are shown in the record of Proving Tests and the oscillograms attached hereto. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the ratings assigned by the manufacturer as stated below.

For ratings assigned by the manufacturer and proved by test
see page no. 1

The record of Proving Tests apply only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

This Certificate comprises 8 pages, 2 diagrams, 8 oscillograms, 12 photographs,
2 drawings and - other sheets as detailed on page 2

Only integral reproduction of this Certificate, or reproductions of this page accompanied by any page(s) on which are stated the assigned rated characteristics of the apparatus tested, are permitted without written permission from ASTA, 23/24 Market Place, Rugby CV21 3DU England. (see ASTA Publication No.7).

H. G. Patterson ASTA Observer

M. J. Swan Director

25th January 1991 Date