

Supplier Declaration of Conformity (SDOC)

(in accordance with ISO/IEC 17050-1:2004)



SDoC Identification Number: NHPNLINE.002

NHP Electrical Engineering Products (N.Z.) Ltd

118a Carbine Road
Mt Wellington
Auckland 1060
New Zealand
NZ Company No: 931377
Telephone +64 9 276 1967
Fax +64 800 329 647
www.nhp-nz.com

NHP Electrical Engineering Products Pty Ltd

43-67 River Street
Richmond
Victoria 3121
Australia
A.B.N. 84 004 304 812
Telephone +61 3429 2999
Fax +61 3429 1075
www.nhp.com.au

Product details:

Product model:

NHP NLINE - Catalogue No. NL140L and NL340L

Description/Ratings:

Rated Current: 40A
IP66
Voltage rating: 250V 50Hz (NL140L) / 500V 50Hz (NL340L)
Number of Switching Poles: 2 (NL140L) / 3 (NL340L)
AC21 rating: 40A, AC22 rating: 40A, AC23 rating: 16A
M-Rating: M180 (NL140L & NL340L)

The products listed above is in conformity with the following Standard(s)/Normative Documents:

Standard/Document:

AS/NZS 3133:2008 Inc. Amendment 1 and 2
AS/NZS 3947.3:2001
AS 60529

Test reports/Certificates:

TUV016977E Certificate of Suitability - 3133:2008 Inc. Amendment 1 and 2

Product Markings:

RCM mark



Name: Christian James

Position: Product Manager Plug/Sockets & Terminations

Date: 30/04/2014

**Signature of
Authorised Person:**

